

# Result Summary Report

Program:

Date Range:

Water Utility:

Supply System:

Drinking Water Monitoring Program

01-11-2024 - 30-11-2024

Yenda GT02

Barcode:

Analysis Type:

Characteristics:

Sample Types:

All

All

All

All

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.2900	1.2650	0.2214	1.05	1.58	4	0	1.58	1.05	100.00
	pH	6.5 - 8.5		7.3550	7.3550	0.0569	7.29	7.42	4	0	7.42	7.29	100.00
	Temperature	30.0000	C	21.4500	20.8000	1.4364	20.6	23.6	4	0	23.6	20.6	100.00
	Total Chlorine	5.0000	mg/L	1.5175	1.5050	0.2787	1.19	1.87	4	0	1.87	1.19	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1250	0.1200	0.0370	0.09	0.17	4	0	0.17	0.09	100.00